

D5000M Modbus Register Map				
Function	Register	Direction	Value	Description
04	30001	Read	0.FFFF	Channel 0 Data Value
04	30002	Read	0.FFFF	Channel 1 Data Value
04	30003	Read	0.FFFF	Channel 2 Data Value
04	30004	Read	0.FFFF	Channel 3 Data Value
06	40001	Read	0	Always Returns Zero
06	40001	Write	0	Temporarily suspend Modbus RTU and return back to DGH ASCII protocol.